

From WorkSafeBC publication, WS 2013-03

Material	Minimum Amount
Asbestos ropes, gaskets, wires, etc.	5 linear cm (2 linear in) or 5 cm x 5 cm (2 in. x 2 in.)
Asbestos cement board	5 cm x 5 cm (2 in. x 2 in.)
Asphalt shingles	5 cm x 5 cm (2 in. x 2 in.)
Ceiling tiles	5 cm x 5 cm (2 in. x 2 in.)
Drywall mud	5 cm x 5 cm (2 in. x 2 in.) – Mud only, do not include the gypsum board or drywall tape
Floor tile, linoleum, asphalt flooring	5 cm x 5 cm (2 in. x 2 in.)
Levelling compounds and mortars	50 cm ³ (3 cu. In.)
Mastics and putties	15 cm ³ (1 cu. In.)
Mechanical insulation (piping)	50 cm ³ (3 cu. In.) – All layers must be collected, down to the pipe
Roofing felt	5 cm x 5 cm (2 in. x 2 in.) – All layers must be collected, down to the sheathing
Sprayed insulation (e.g. sprayed fireproofing)	50 cm ³ (3 cu. In.)
Texture coats and stuccoes	50 cm ³ (3 cu. In.)
Vermiculite insulation	4L (1 gal.) – Collect from the top to the bottom of the application to get a representative sample
Other non-friable products	5 cm x 5 cm (2 in. x 2 in.)
Other sprayed materials	1 full, small zip-lock bag